



Louisville Fire Protection District
895 West Via Appia
Louisville Colorado, 80027

Louisville Fire Protection District Fire Safety Inspection Checklist for Mobile Food Vending

Portable Fire Extinguishers

- ☐ Are portable fire extinguishers charged and in operating condition?
- ☐ Are portable fire extinguisher obstructed?

Hood Fire Suppression System

- ☐ Is the hood fire suppression system charged and in operating conditions?
- ☐ Are the filters cleaned of all grease?

Propane

- ☐ Is the propane system inspected prior to use?
- ☐ Are the propane tanks secured in an upright position?
- ☐ Are the propane bottles within their hydrostatic test date?
- ☐ Is the propane system in good condition (i.e. no leaks, rust)?
- ☐ Has the propane system been leak tested?
- ☐ Is the main shut-off marked, in plain view and easily assessable?
- ☐ Is the fuel supply shut off when not in use and while in transit?

Electrical

- ☐ Is the electrical system in good working condition?
- ☐ Are extension cords in good condition?

Generators

- ☐ Are generators placed at least 10' from buildings?
- ☐ Are generator exhaust directed away from the mobile cooking vehicle, buildings, exits and openings?
- ☐ Are generators protected from contact by the public?
- ☐ Are fuel supplies properly stored?
- ☐ When refueling are the generators shut down, cooled and then refueled?

Solid fuel

- ☐ Is combustible solid fuel properly stored away from heat producing appliances?
- ☐ Are ashes, cinders, and other fire debris removed at the end of the day and stored in a proper container away from the vehicle, buildings and combustibles?

Note: If you have any questions please feel free to contact the Fire Prevention Division at 303-666-8809.